

Section View - Typical Installation

1.	General 4' diameter Manhole spec.	- can be used for Sewer,	Drain Manholes & Catch Basins
----	-----------------------------------	--------------------------	-------------------------------

- 2. Concrete strength f'c 4000PSI@28 days. Density 150 PCF.
- 3. Cement, Portland Type II or III, ASTM C150-18.
- 4. Reinforced Steel conforms to latest ASTM A1064 Spec. 0.12 SQ. IN./Lineal FT. and 0.12 SQ IN. (Both ways) Base Bottom.
  - 5. Admixtures, air & plasticizers per ASTM C1116, C494, C260 and C1017.
  - 6. H20 & HL-93 Design Loading AASHTO HS-20-44; ASTM C478 specs for precast reinforced concrete manhole sections.
  - 7. Butyl resin joint seal conforms to latest ASTM C913, C990 & C443 specs.
  - 8. Optional steel reinforced plastic steps meet ASTM A615 MA Industries type PS-2-PR-SL.
  - 9. Holes cored to your plans/specifications. Drawings or plans must be submitted prior to any coring.
  - 10. Sewer Manholes are spray coated w/Aqua Safe Waterproofer

Notes

## 87 Adams Hill Road, PO Box #333 Greenville, NH 03048 603-878-1340